

## FIRE SAFETY CERTIFICATE

No. MBMC/FIRE/287/2024-25

Dated: 06/06/2024

Certified that the Uttan Vividh Lakshya Shiksha <sup>Gansthya</sup> (name of the building) Ram Ratna Vidya Mandir (premises) Keshav Srushti Uttan Village Bhayander (W) (address) comprised of ..... basement(s) and ..... G.t. 2 and G.t. 3 ..... (upper floors) owned/ occupied by Ram Ratna Vidya Mandir ..... (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 05/01/2024 (date of inspection) in the presence of Anu Verma ..... (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII ..... ( XI XII) With effect from 12/01/2024 for a period of 31/12/2024 year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Wet Riser
2. Down Comer System
3. Court yard
4. Fire Extinguisher 17 Nos.

Issued on 12/01/2024 (date of issue) at MBMC FIRE Bhayander (W) (place) by

\*Strike out whichever is not applicable.

Signature with Seal: .....

Name

Dr. P. S. Borade


Designation

Name &amp; Address of Department/ Office

A CHIEF FIRE OFFICER  
FIRE & EMERGENCY SERVICES  
MIRA-BHAINDIR MUNICIPAL CORPORATION

To Ram Ratna Vidya Mandir  
Keshav Srushti Uttan Bhayander (W)

(Name &amp; Address of the Institution)



ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to .....  
(reasons to be recorded).

(Name and designation of the authorized signatory)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



# MIRA-BHAYANDAR MUNICIPAL CORPORATION

## FIRE DEPARTMENT

Tel. No. 2819 76 37 / 101



MBMC / FIRE / 1506 / 2023-24

DATE: 12 / 01 / 2024

To,  
M/s Uttan Vividh Lakshyee Shikshan Sanstha  
S. No./H. No. (Old) 200pt at Village Uttan,

Sub. :- Renewal of No Objection Certificate for "Auditorium (Assembly Hall) Building"  
On Land bearing S.No./ H. No. 200pt at Village Uttan & Dist. Thane.

### BUILDING KNOWN AS "AUDITORIUM (ASSEMBLY HALL)"

- Ref. 1) An Application received from Uttan Vividh Lakshyee Shikshan Sanstha Dt : 05/01/2024.  
2) Renewal Noc MBMC/ FIRE/2092/2022-23 Dated: 14/03/2023  
3) Fire Fighting System Maintenance Certificate of M/s. J. L. Fire Solutions pvt. Ltd.  
Dt : 12/01/2024 (Form B)

With reference to above application dated on 05/01/2024 (Ref.No. 1) the party has Submitted The Maintenance Report for the "Auditorium (Assembly Hall) G + 2 Floor" situated on the above mentioned S. No. / H. No. From the point of view of fire prevention & protection provided by M/s. UTTAN VIVIDH LAKSHYEE SHIKSHAN SANSTHA" Following Fire Fighting arrangements provided were found in satisfactory working condition as per the certificate issued by the Licensed Agency.

- A) Wet Riser / Sprinkler System  
a) Booster Pump- 01 Nos.  
b) Main Pump 50 HP - 01 Nos.  
c) Jockey Pump 15 HP -01 Nos.  
d) Hydrant Valve -05 Nos.  
e) Hose Box with Canvas & Branch Pipe - 05 Nos.  
f) Fire Inlet - 1 Nos.  
g) Fire and Sand Bucket- 12 Nos.  
B) Fire Extinguisher ABC Type 9 kg – 2 Nos.  
C) Fire Extinguisher ABC Type 6 kg – 17 Nos.

Considering the same this Office is issuing Renewal of final No Objection certificate for the above mentioned building. This Certificate shall be treated valid up to 31/12/2024. It is the responsibility of the owner / Architect / occupier to get the same renewed every year from the Fire Brigade Department after submitting inspection Report from Licensed Contractor twice in a year that is on 1<sup>st</sup> January and on 1<sup>st</sup> July. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be Personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The party has paid Inspection fees Rs.30,065/- & Renewal fee of Rs. 1,100/- Vide Receipt No. 393556 dated :- 12/01/2024.

A. CHIEF FIRE OFFICER  
FIRE & EMERGENCY SERVICES  
MIRA-BHAYANDAR MUNICIPAL CORPORATION

Please Note:- The Developer/Owner/Occupier have to Renew the N.O.C. on 1<sup>st</sup> Jan. of every year & submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Government of Maharashtra on 1<sup>st</sup> July of every year. The list of the License Agencies is available on www.maharashtrafireservices.org Or www.mfsindia.org.



# MIRA-BHAYANDAR MUNICIPAL CORPORATION

## FIRE DEPARTMENT

Tel. No. 2819 76 37 / 101



MBMC / FIRE / 1507 / 2023-24

DATE: 12/01/2024

To,  
M/s Uttan Vividh Lakshyee Shikshan Sanstha  
S. No./H. No. (Old) 200pt at Village Uttan,

Sub. :- Renewal of No Objection Certificate for "Ram Ratna Vidya Mandir Building No. 3, 4, & Hostel Building 5 & 6" and on land bearing S. No./H. No. (Old) 200pt at Village Uttan, Tal. & Dist. Thane.

### BUILDING KNOWN AS "UTTAN VIVIDH LAKSHYEE SHIKSHAN SANSTHA"

Ref. 1) An Application received from Uttan Vividh Lakshyee Shikshan Sanstha Dt :05/01/2024

2) Renewal Noc MBMC/ FIRE/2094/2022-23 Dated: 14/03/2023.

3) Fire Fighting System Maintenance Certificate of M/s. J. L. Fire Solutions pvt. Ltd.  
Dt : 12/01/2024 (Form B)

With reference to above application dated on 05/01/2024 (Ref. No. 1) the party has Submitted The Maintenance Report for the "Ram Ratna VidyaMandir Building 3 G + 2 Floors,& Building No. 4 G + 3 Floors & Hostel Building No. 5 & 6 G + 4 Floors" situated on the above mentioned S.No./H. No. From he point of view of fire prevention & protection provided by M/s. UTTAN VIVIDH LAKSHYEE SHIKSHAN SANSTHA" Following Fire Fighting arrangements provided were found in satisfactory working condition as per the certificate issued by the Licensed Agency.

- A) Down Comer system
  - a) On every floor hose reel hose & landing valve / Hydrant Valve,
  - b) Booster pump on terrace- 5 HP for each Bldg.
  - c) Fire Brigade inlet at ground floor.
  - d) Main Pump – 30 HP 3 Nos. (Combine for Bldg. No. 3, 4 & 6)
  - e) Jockey Pump – 10 HP for School Building
- B) Fire Extinguishers -17nos
- C) Court Yard.

Considering the same this Office is issuing Renewal of final No Objection certificate for the above mentioned building. This Certificate shall be treated valid up to 31/12/2024. It is the responsibility of the owner / Architect / occupier to get the same renewed every year from the Fire Brigade Department after submitting inspection Report from Licensed Contractor twice in a year that is on 1<sup>st</sup> January and on 1<sup>st</sup> July. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be Personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The party has paid Inspection fees Rs.72,682/- And Renewal fees of Rs. 1,100/-Vide Receipt No. 393556 dated :- 12/01/2024.

  
A. CHIEF FIRE OFFICER  
FIRE & EMERGENCY SERVICES  
MIRA-BHAYANDAR MUNICIPAL CORPORATION

Please Note:- The Developer/Owner/Occupier have to Renew the N.O.C. on 1<sup>st</sup> Jan. of every year & submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Government of Maharashtra on 1<sup>st</sup> July of every year. The list of the License Agencies is available on [www.maharashtrafireservices.org](http://www.maharashtrafireservices.org) Or [www.mfsindia.org](http://www.mfsindia.org).